

03 June 2026

Dear Bidder

RE: RESPONSE TO QUERY: COMPETITIVE BIDDING TENDER DOMESTIC (CBTD) 40-2026 FOR THE PROVISION OF A CONTRACTOR FOR THE CONSTRUCTION OF PLINTHS ON A SUPPLY AND FIX BASIS

The above tender wherein you are participating, refers.

Please be advised that we received a query from one of the participating bidders. The query together with the response from TelOne is as below:

Query 1

After reviewing the document, we humbly seek clarification on the following areas to enable accurate and responsive pricing;

- i) The diagrams are illegible, kindly send diagrams that we can read so that we be able to properly quantify for the works.
- ii) Because the diagram and the notes aren't clear we also failed to establish how many plinths are to be on each site and what sizes.

Response 1

- i) Please find below the clear diagram;

OUTSIDE CABINET FOUNDATION LAYOUT

B-B SECTION

A-A SECTION

L(mm)	W(mm)	H(mm)	R.C.(m ³)	P.C.(m ³)
3000	1500	200	0.60	0.51

No	SIZE	SHAPE	UNIT LENGTH	Quantity	TOTAL LENGTH
1	Ø10	30 1900 50	3000	4	12000
2	Ø10	50 900 50	1000	14	14000

Note:

- All dimension are in Millimeters(mm), and all level in Meter(m), unless otherwise noted.
- Steel grade for diameter 12 and below shall no less than S-300Mpa, for diameters 14 and above the steel grade shall no less than S-300Mpa.
- Compaction strength of the plain concrete shall no less than 10Mpa(C10), for reinforced concrete the strength shall no less than 25Mpa(C25).
- The thickness of concrete cover for reinforcement is 50mm for foundation.
- Soil under the foundation shall be solid, otherwise well compacted soil shall be provided.

Outdoor Cabinet Foundation Design

LXW Dimensions of Plinths

Cabinet plinth is 1000mm x 2000mm

DEG plinth is 1000mm x 3000mm

- ii) Please note that page 10,11 and 12 of the tender document has been amended to reflect the quantities on each site as follows;

A	B	Quantity	C
Item No	Item description and full technical Specification required (including applicable standards)		{Confirm full specification of items offered by Bidder <u>and</u> compliance of items to detail in column b} <u>Compliance Status</u> C-Compliant NC- Non Compliant
	PROVISION OF A CONTRACTOR FOR THE CONSTRUCTION OF DEG PLINTHS AND FOUNDATIONAL SLABS ON A SUPPLY AND FIX BASIS		
1	Foundational Slabs (Harare)	10	
2	Foundational Slabs (Bulawayo)	5	
3	Foundational Slabs (Midlands)	5	
4	Foundational Slabs (Manicaland)	4	
5	Foundational Slabs (Mat. South)	1	
6	DEG Plinths (Harare)	10	
7	DEG Plinths (Bulawayo)	5	
8	DEG Plinths (Midlands)	5	
9	DEG Plinths (Manicaland)	4	
10	DEG Plinths (Mat.South)	1	

Please be advised that the closing date for the tender has been extended from 04 June 2026 to 09 June 2026. The time and place remain the same.

Yours faithfully



C. CHENGA (MCIPS)
PROCUREMENT MANAGEMENT UNIT EXECUTIVE